

13-6-2 Culinary Water

In subdivisions utilizing a central water system:

(a) Both "offsite" and "onsite" water mains of not less than 6 inches in diameter shall be installed in such a way that each lot may be served therefrom.

(b) Water service laterals shall be installed from main line to the outer edge of any road proposed to be dedicated to the County. Said lateral shall include the installation of a meter box and meter setter.

(c) The water flowing to said system shall be from a source and through lines which are sufficient in size to provide a volume of flow and level of pressure adequate to meet State Health standards.

(d) The quality of materials and procedures of construction shall conform to County standards.

13-6-2-2 In Subdivisions utilizing individual wells.

Construction of wells will be required as a condition for granting of a building permit, but no water quality standards are required for wells serving less than _ ____ households. (*Res. 10-3-84A*)